

**CLIENT:** DASSO USA  
6060 Boat Rock Blvd. SW, Suite 800  
Atlanta, GA 30336

**Project No:** 20-2258

**Report Date:** May 7, 2021

**SAMPLE ID:** Series: DassoXTR Fused Bamboo Decking

**SAMPLE DESCRIPTION:** 0.8" and 2.0" thick; See page 4, 12, 20 and 28 for full description.

**SAMPLING DETAIL:** Test samples were witnessed at the location of manufacture in Xiandai Zhuchanye Yuanqu, Gaobu Town, Gaobu Town, Zixi Country, Fuzhou City, Jiangxi Province China by QAI personnel Fey Han on July 31, 2020.

**DATE OF RECEIPT:** Samples were received at the FTL Miami Laboratory on March 29, 2021

**TESTING PERIOD:** April 12, 2021 through April 28, 2021

**TESTING LOCATION:** Fenestration Testing Laboratory (FTL) – Miami, Florida, USA

**AUTHORIZATION:** Proposal 20JL09183, signed by Avery Chua, dated September 29, 2020.

**TEST PROCEDURE:** Testing to the following requirements:

- ASTM E330-14 Standard Test Method for Structural Performance of Exterior Windows, Doors, Skylights and Curtain Walls by Uniform Static Air Pressure Difference

**TEST RESULTS:** The bamboo decking achieved passing results found on pages 4-35 of this test report when tested in accordance with the ASTM E330.


**CONTENTS:** Test report pages 1 through 36.

**Prepared By**

*Lusinda Delgado*

**Lusinda Delgado**  
Technical Report Writer

**Signed for and on behalf of  
Fenestration Testing Laboratory**



**Jose Sanchez**  
Operation Manager

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

**Table of Contents**

<b>Samples A-1, A-2, A-3 and A-4</b>				<b>Samples C-1, C-2, C-3 and C-4</b>			
		Page	Rev			Page	Rev
Description of Test Sample		4		Description of Test Sample		20	
Decking		4		Decking		20	
Sample Installation		4		Sample Installation		20	
<b>Results Sample A-1</b>				<b>Results Sample C-1</b>			
Load Test Negative	ASTM E330	4-5		Load Test Negative	ASTM E330	20-21	
<b>Results Sample A-2</b>				<b>Results Sample C-2</b>			
Load Test Negative	ASTM E330	6-7		Load Test Negative	ASTM E330	22-23	
<b>Results Sample A-3</b>				<b>Results Sample C-3</b>			
Load Test Negative	ASTM E330	8-9		Load Test Negative	ASTM E330	24-25	
<b>Results Sample A-4</b>				<b>Results Sample C-4</b>			
Load Test Positive	ASTM E330	10-11		Load Test Positive	ASTM E330	26-27	
<b>Samples B-1, B-2, B-3 and B-4</b>				<b>Samples D-1, D-2, D-3 and D-4</b>			
Description of Test Sample		12		Description of Test Sample		28	
Decking		12		Decking		28	
Sample Installation		12		Sample Installation		28	
<b>Results Sample B-1</b>				<b>Results Sample D-1</b>			
Load Test Negative	ASTM E330	12-13		Load Test Negative	ASTM E330	28-29	
<b>Results Sample B-2</b>				<b>Results Sample D-2</b>			
Load Test Negative	ASTM E330	14-15		Load Test Negative	ASTM E330	30-31	
<b>Results Sample B-3</b>				<b>Results Sample D-3</b>			
Load Test Negative	ASTM E330	16-17		Load Test Negative	ASTM E330	32-33	
<b>Results Sample B-4</b>				<b>Results Sample D-4</b>			
Load Test Positive	ASTM E330	18-19		Load Test Positive	ASTM E330	34-35	

Technician:  
 Yoenis Gonzalez

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

Revision	Description	Effective Date
0	Initial Release	5/7/2021

Notes
<p>* designates measurements by laboratory            ** as per manufacturer</p> <p>Drawings referenced in this document are an integral part of this report, therefore, are required when distributing this test report. Test results obtained represent the actual value of the tested specimens and do not constitute opinion or endorsement by this laboratory.</p> <p>At conclusion of the below tests, there was no apparent damage to sample or fasteners. Test specimens were covered with 1.5 mil plastic sheeting to seal from air leakage when load test were performed, however this had no effect on above results.</p>

Remarks
<p>Detailed drawings and official test report will be retained by Fenestration Testing Laboratory for a period of five years from the original test date.</p> <p>This product was tested in accordance with the ASTM E330-14 and meets the requirements of the standard.</p>

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

DESCRIPTION OF SAMPLE	
Model Designation:	1" x 6" x 0.8" DassoXTR Fused Bamboo Decking Classic Espresso with Hidden Clips
Overall Size:	8'-0" (96") x 4'-0" (48") wide
Samples A-1, A-2, A-3 and A-4	

Decking
2x6 yellow pine wood joist spaced 24" on center.

Sample Installation
The bamboo decking was installed to the wood joist using a metallic **Panda Claw hidden clip at each joist location. The hidden clips were fastened to the joist using one No. 7 x 1 3/4" flat head stainless steel wood screw.

<b>Sample: A-1</b>	<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg		
<b>Title of Test</b>	<b>Pressure</b>	<b>Notes</b>		
Load Test Negative Load	20.0 psf			
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.025"	None	Passed	

<b>Sample: A-1</b>	<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg		
<b>Title of Test</b>	<b>Pressure</b>	<b>Notes</b>		
Load Test Negative Load	40.0 psf			
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.052"	0.001"	Passed	

<b>Sample: A-1</b>	<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg		
<b>Title of Test</b>	<b>Pressure</b>	<b>Notes</b>		
Load Test Negative Load	60.0 psf			
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.092"	0.003"	Passed	

<b>Sample: A-1</b>	<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg		
<b>Title of Test</b>	<b>Pressure</b>	<b>Notes</b>		
Load Test Negative Load	80.0 psf			
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.136"	0.005"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: A-1</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		100.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.171"	0.008"	Passed	

<b>Sample: A-1</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		120.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.219"	0.009"	Passed	

<b>Sample: A-1</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		140.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	n/a	n/a	Failed	Deck panel pulled away from the Panda Clip at 138.0 psf

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: A-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		20.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.021"	None	Passed	

<b>Sample: A-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		40.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.056"	0.001"	Passed	

<b>Sample: A-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		60.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.089"	0.002"	Passed	

<b>Sample: A-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		80.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.124"	0.003"	Passed	

<b>Sample: A-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		100.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.164"	0.006"	Passed	

<b>Sample: A-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		120.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.226"	0.011"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: A-2</b>		<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		140.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	n/a	n/a	Failed	Deck panel pulled away from the Panda Clip at 134.0 psf

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: A-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		20.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.039"	None	Passed	

<b>Sample: A-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		40.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.063"	None	Passed	

<b>Sample: A-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		60.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.104"	0.002"	Passed	

<b>Sample: A-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		80.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.139"	0.005"	Passed	

<b>Sample: A-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		100.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.175"	0.009"	Passed	

<b>Sample: A-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		120.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.241"	0.010"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.



<b>Sample: A-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		140.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.292"	0.014"	Passed	

<b>Sample: A-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		160.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	n/a	n/a	Failed	Deck panel pulled away from the Panda Clip at 142.0 psf

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: A-4</b>		<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		20.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.032"	0.001"	Passed	

<b>Sample: A-4</b>		<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		40.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.055"	0.002"	Passed	

<b>Sample: A-4</b>		<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		60.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.074"	0.003"	Passed	

<b>Sample: A-4</b>		<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		80.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.086"	0.003"	Passed	

<b>Sample: A-4</b>		<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		100.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.122"	0.005"	Passed	

<b>Sample: A-4</b>		<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		120.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.161"	0.006"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: A-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		140.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.169"	0.007"	Passed	

<b>Sample: A-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		160.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.173"	0.007"	Passed	

<b>Sample: A-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		180.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.179"	0.008"	Passed	

<b>Sample: A-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		200.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.186"	0.009"	Passed	

<b>Sample: A-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		220.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.193"	0.011"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

DESCRIPTION OF SAMPLE	
Model Designation:	1" x 6" x 2.0" DassoXTR Fused Bamboo Decking Classic Espresso with Face Fasteners
Overall Size:	8'-0" (96") x 4'-0" (48") wide
Samples B-1, B-2, B-3 and B-4	

Decking
2x6 yellow pine wood joist spaced 24" on center.

Sample Installation
The bamboo decking was installed to the wood joist using two No. 10 x 3 1/2" pan head stainless steel sheet metal screws at each joist location, 2" from the butt end.

<b>Sample: B-1</b>	<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg		
<b>Title of Test</b>	<b>Pressure</b>	<b>Notes</b>		
Load Test Negative Load	28.75 psf			
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.031"	None	Passed	

<b>Sample: B-1</b>	<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg		
<b>Title of Test</b>	<b>Pressure</b>	<b>Notes</b>		
Load Test Negative Load	57.5 psf			
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.059"	0.001"	Passed	

<b>Sample: B-1</b>	<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg		
<b>Title of Test</b>	<b>Pressure</b>	<b>Notes</b>		
Load Test Negative Load	86.25 psf			
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.069"	0.002"	Passed	

<b>Sample: B-1</b>	<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg		
<b>Title of Test</b>	<b>Pressure</b>	<b>Notes</b>		
Load Test Negative Load	115.0 psf			
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.096"	0.002"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: B-1</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		143.75 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.115"	0.003"	Passed	

<b>Sample: B-1</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		172.5 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.165"	0.005"	Passed	

<b>Sample: B-1</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		201.25 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.179"	0.008"	Passed	

<b>Sample: B-1</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		230.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	n/a	n/a	Failed	Deck panel fastener pulled away from the joist at 221.0 psf

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: B-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		28.75 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.051"	0.001"	Passed	

<b>Sample: B-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		57.5 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.073"	0.002"	Passed	

<b>Sample: B-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		86.25 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.082"	0.003"	Passed	

<b>Sample: B-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		115.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.105"	0.003"	Passed	

<b>Sample: B-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		143.75 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.139"	0.005"	Passed	

<b>Sample: B-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		172.5 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.186"	0.010"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: B-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		201.25 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.196"	0.012"	Passed	

<b>Sample: B-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		230.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	n/a	n/a	Failed	Deck panel fastener pulled away from the joist at 228.0 psf

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: B-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		28.75 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.031"	None	Passed	

<b>Sample: B-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		57.5 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.063"	None	Passed	

<b>Sample: B-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		86.25 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.081"	0.001"	Passed	

<b>Sample: B-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		115.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.090"	0.002"	Passed	

<b>Sample: B-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		143.75 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.109"	0.005"	Passed	

<b>Sample: B-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		172.5 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.182"	0.008"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.



<b>Sample: B-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		201.25 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.199"	0.013"	Passed	

<b>Sample: B-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		230.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	n/a	n/a	Failed	12 seconds into the test the deck panel fastener pulled away from the joist

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: B-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		28.75 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.041"	None	Passed	

<b>Sample: B-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		57.5 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.060"	0.001"	Passed	

<b>Sample: B-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		86.25 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.080"	0.002"	Passed	

<b>Sample: B-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		115.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.072"	0.002"	Passed	

<b>Sample: B-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		143.75 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.092"	0.003"	Passed	

<b>Sample: B-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		172.5 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.126"	0.004"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: B-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		201.25 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.139"	0.005"	Passed	

<b>Sample: B-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		230.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.146"	0.008"	Passed	

<b>Sample: B-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		258.75 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.159"	0.009"	Passed	

<b>Sample: B-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		287.5 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.163"	0.012"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

DESCRIPTION OF SAMPLE	
Model Designation:	1" x 6" x 0.8" DassoXTR Fused Bamboo Decking Epic Cognac with Hidden Clips
Overall Size:	8'-0" (96") x 4'-0" (48") wide
Samples C-1, C-2, C-3 and C-4	

Decking
2x6 yellow pine wood joist spaced 24" on center.

Sample Installation
The bamboo decking was installed to the wood joist using a metallic **Panda Claw hidden clip at each joist location. The hidden clips were fastened to the joist using one No. 7 x 1 3/4" flat head stainless steel wood screw.

<b>Sample: C-1</b>	<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg		
<b>Title of Test</b>	<b>Pressure</b>	<b>Notes</b>		
Load Test Negative Load	20.0 psf			
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.039"	None	Passed	

<b>Sample: C-1</b>	<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg		
<b>Title of Test</b>	<b>Pressure</b>	<b>Notes</b>		
Load Test Negative Load	40.0 psf			
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.063"	0.001"	Passed	

<b>Sample: C-1</b>	<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg		
<b>Title of Test</b>	<b>Pressure</b>	<b>Notes</b>		
Load Test Negative Load	60.0 psf			
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.096"	0.002"	Passed	

<b>Sample: C-1</b>	<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg		
<b>Title of Test</b>	<b>Pressure</b>	<b>Notes</b>		
Load Test Negative Load	80.0 psf			
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.122"	0.003"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: C-1</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		100.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.141"	0.005"	Passed	

<b>Sample: C-1</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		120.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.205"	0.006"	Passed	

<b>Sample: C-1</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		140.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	n/a	n/a	Failed	Deck panel pulled away from the Panda Clip at 131.0 psf

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: C-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		20.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.031"	None	Passed	

<b>Sample: C-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		40.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.059"	0.001"	Passed	

<b>Sample: C-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		60.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.093"	0.002"	Passed	

<b>Sample: C-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		80.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.130"	0.005"	Passed	

<b>Sample: C-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		100.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.162"	0.005"	Passed	

<b>Sample: C-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		120.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.245"	0.006"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: C-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		140.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	n/a	n/a	Failed	Deck panel pulled away from the Panda Clip at 139.0 psf

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: C-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		20.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.029"	None	Passed	

<b>Sample: C-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		40.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.049"	None	Passed	

<b>Sample: C-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		60.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.082"	0.002"	Passed	

<b>Sample: C-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		80.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.142"	0.007"	Passed	

<b>Sample: C-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		100.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.153"	0.009"	Passed	

<b>Sample: C-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		120.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.255"	0.012"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.



<b>Sample: C-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		140.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	n/a	n/a	Failed	Deck panel pulled away from the Panda Clip at 139.0 psf

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: C-4</b>		<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		20.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.021"	None	Passed	

<b>Sample: C-4</b>		<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		40.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.039"	None	Passed	

<b>Sample: C-4</b>		<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		60.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.063"	None	Passed	

<b>Sample: C-4</b>		<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		80.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.094"	0.002"	Passed	

<b>Sample: C-4</b>		<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		100.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.116"	0.004"	Passed	

<b>Sample: C-4</b>		<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		120.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.169"	0.008"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: C-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		140.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.176"	0.009"	Passed	

<b>Sample: C-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		160.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.181"	0.010"	Passed	

<b>Sample: C-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		180.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.189"	0.012"	Passed	

<b>Sample: C-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		200.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.196"	0.015"	Passed	

<b>Sample: C-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		220.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.203"	0.016"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

DESCRIPTION OF SAMPLE	
Model Designation:	1" x 6" x 2" DassoXTR Fused Bamboo Decking Epic Cognac with Face Fasteners
Overall Size:	8'-0" (96") x 4'-0" (48") wide
Samples D-1, D-2, D-3 and D-4	

Decking
2x6 yellow pine wood joist spaced 24" on center.

Sample Installation
The bamboo decking was installed to the wood joist using two No. 10 x 3 1/2" pan head stainless steel sheet metal screws at each joist location, 2" from the butt end.

<b>Sample: D-1</b>	<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg		
<b>Title of Test</b>	<b>Pressure</b>	<b>Notes</b>		
Load Test Negative Load	28.75 psf			
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.032"	None	Passed	

<b>Sample: D-1</b>	<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg		
<b>Title of Test</b>	<b>Pressure</b>	<b>Notes</b>		
Load Test Negative Load	57.50 psf			
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.051"	None	Passed	

<b>Sample: D-1</b>	<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg		
<b>Title of Test</b>	<b>Pressure</b>	<b>Notes</b>		
Load Test Negative Load	86.25 psf			
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.063"	0.001"	Passed	

<b>Sample: D-1</b>	<b>Temperature:</b> 75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg		
<b>Title of Test</b>	<b>Pressure</b>	<b>Notes</b>		
Load Test Negative Load	115.0 psf			
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.089"	0.002"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: D-1</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		143.75 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.089"	0.002"	Passed	

<b>Sample: D-1</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		172.5 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.172"	0.007"	Passed	

<b>Sample: D-1</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		201.25 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.188"	0.009"	Passed	

<b>Sample: D-1</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		230.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	n/a	n/a	Failed	Deck panel fastener pulled away from the joist at 226.0 psf

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: D-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		28.75 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.029"	None	Passed	

<b>Sample: D-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		57.5 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.053"	None	Passed	

<b>Sample: D-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		86.25 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.073"	0.001"	Passed	

<b>Sample: D-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		115.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.111"	0.003"	Passed	

<b>Sample: D-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		143.75 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.162"	0.005"	Passed	

<b>Sample: D-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		172.5 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.193"	0.008"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: D-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		201.25 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.199"	0.009"	Passed	

<b>Sample: D-2</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		230.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	n/a	n/a	Failed	Deck panel fastener pulled away from the joist at 229.0 psf

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: D-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		28.75 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.025"	None	Passed	

<b>Sample: D-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		57.5 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.038"	None	Passed	

<b>Sample: D-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		86.25 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.058"	None	Passed	

<b>Sample: D-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		115.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.095"	0.003"	Passed	

<b>Sample: D-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		143.75 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.109"	0.003"	Passed	

<b>Sample: D-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		172.5 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.174"	0.009"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.



<b>Sample: D-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		201.25 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.192"	0.009"	Passed	

<b>Sample: D-3</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Negative Load		230.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	n/a	n/a	Failed	Deck panel fastener pulled away from the joist at 229.0 psf

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: D-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		28.75 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.019"	None	Passed	

<b>Sample: D-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		57.5 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.039"	None	Passed	

<b>Sample: D-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		86.25 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.053"	None	Passed	

<b>Sample: D-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		115.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.083"	0.004"	Passed	

<b>Sample: D-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		143.75 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.109"	0.006"	Passed	

<b>Sample: D-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		172.5 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.133"	0.006"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

<b>Sample: D-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		201.25 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.142"	0.007"	Passed	

<b>Sample: D-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		230.0 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.149"	0.008"	Passed	

<b>Sample: D-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		258.75 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.161"	0.011"	Passed	

<b>Sample: D-4</b>	<b>Temperature:</b>	75.3°F	<b>Barometric Reading:</b> 30.21 inches Hg	
<b>Title of Test</b>		<b>Pressure</b>	<b>Notes</b>	
Load Test Positive Load		287.50 psf		
See Appendix A				
<b>Reading#</b>	<b>Deflection</b>	<b>Permanent Set</b>	<b>Results</b>	<b>Add. Info</b>
1	0.169"	0.012"	Passed	

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.

Appendix A

			1			

THIS REPORT IS THE CONFIDENTIAL PROPERTY OF THE CLIENT ADDRESSED. THE REPORT MAY ONLY BE REPRODUCED IN FULL. PUBLICATION OF EXTRACTS FROM THIS REPORT IS NOT PERMITTED WITHOUT WRITTEN APPROVAL FROM QAI. ANY LIABILITY ATTACHED THERETO IS LIMITED TO THE FEE CHARGED FOR THE INDIVIDUAL PROJECT FILE REFERENCED. THE RESULTS OF THIS REPORT PERTAIN ONLY TO THE SPECIFIC SAMPLE(S) EVALUATED. UNLESS SPECIFICALLY STATED OR IDENTIFIED OTHERWISE, QAI HAS UNTILIZED A SIMPLE ACCEPTANCE RULE TO MAKE CONFORMITY DECISIONS ON TESTING RESULTS CONTAINED IN THIS REPORT, AS APPLICABLE.